


VAULT LID



LID DETAIL

NOTES:

- 1 - ALL CONCRETE SHALL HAVE 5% AIR ENTRAINMENT AND TEST 4000#, SURFACE SHALL HAVE A STEEL TROWEL FINISH.
- 2 - LID MATERIAL: STEEL, HOT DIPPED GALVANIZED AFTER FABRICATION.



DATE: 08/27/04

REVISED: 09/16/04

4' x 6' VAULT LID

STANDARD NUMBER
UE346VL

ASSEMBLY

Item #	Quantity	Stock #	Stock Description
76	1	30-350-30	FORMICA SWITCHPLATE, UG
144	1	44-004-12	4' X 6' VAULT LID



4' X 6' VAULT LID

Date:

STANDARD
NUMBER
UE346VL