



1. SERVICE & CONNECTIONS BY I.P. & L. (NOT TO EXCEED 125')
2. CABLE CONTINUOUS TO METER.
3. CUSTOMER'S WIRES AND EQUIPMENT.
4. CUSTOMER TO OWN AND INSTALL GUY & ANCHOR. (WHEN USED)
5. CUSTOMER OWN AND INSTALL N.E.C. APPROVED 2" SERVICE MAST WITH ENTRANCE HEAD.
6. CUSTOMER TO INSTALL METER ENCLOSURE AND 2" HUB FURNISHED BY I.P. & L.
7. CUSTOMER TO OWN AND INSTALL ENCLOSED MAIN BREAKER.
8. CUSTOMER TO OWN & INSTALL #6 C.U. GROUND WIRE & 1/2"X8' GROUND ROD.
9. CUSTOMER TO OWN & INSTALL TREATED TIMBER CRIBING. (IF GUY NOT USED)
10. ALL SCREWS TO BE SLOTTED OR PHILLIPS SHEET METAL TYPE.

- NOTE: 1. CUSTOMER TO OWN AND INSTALL SERVICE POLE, MINIMUM SIZE CLASS 7 & TALL ENOUGH TO PROVIDE THE CLEARANCES SHOWN, MINIMUM POLE SETTING DEPTH IS 10% OF THE LENGTH OF THE POLE PLUS 2' WITH A MINIMUM DEPTH OF 5'.
2. CLEARANCES FOR SERVICE DROP SHOWN ARE THE MINIMUM WITHOUT OTHER ATTACHMENTS TO POLE. IF OTHER FACILITIES ARE ATTACHED, SERVICE POLE SHALL BE OF SUFFICIENT HEIGHT TO MAINTAIN THESE CLEARANCES TO BOTTOM OF POLE & PERMIT A 3'-4" MINIMUM SPACING BELOW THE I.P. & L. SERVICE DROP.
3. CUSTOMER INSTALLATION TO BE INSPECTED BY CITY INSPECTION DIVISION BEFORE CONNECTION BY I.P. & L.



DATE: 01/01/02

REVISED:

LOW VOLTAGE YARD POLE

STANDARD
NUMBER
OSVOHYP